



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
TTY: Contact Through Relay  
Jim Doyle, Governor  
Richard J. Leinenkugel, Secretary

May 14, 2009

ECOLAB, INC.  
REGULATORY AFFAIRS  
JAMISON KORTAS  
370 N. WABASHA ST.  
ST. PAUL MN 55102-1390

ECOLAB, INC.  
INSTITUTIONAL  
ANI SEUMALO  
370 N. WABASHA ST.  
ST. PAUL MN 55102

Re: Description: PROPORTIONER  
Manufacturer: ECOLAB, INC.  
Product Name: ECOLAB HOUSEKEEPING PRODUCT DISPENSERS  
Model Number(s): DYNAMIX  
Product File No: 20090197

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.11 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2014.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This chemical dispensing system shall be connected to the water distribution system in either of the following manners:
  1. The fixture supply shall be individually connected to the water distribution system.
  2. The fixture supply shall be installed with a pressure bleeding device. The pressure bleeding device shall create a visually free flow of water through the atmosphere from the faucet connection into the fixture drain. The fixture supply must comply with either s. Comm 84.20 (6)(c) and 84.30 (4) or an acceptable backflow preventer must be installed on the inlet of the fixture supply connector and the outlet of the pressure bleeding device.

This approval supersedes the approval issued on August 11, 2004 under product file number 20040035.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040035.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: jerry.thompson@wi.gov